

(Code Change 780CMR3405.3-3-14-06E4)

Amend Section 3405 by adding a new Section, 3405.3 that reads:

3405.3 Carbon Monoxide alarms: Carbon monoxide alarms are required and shall be selected and installed in accordance with the applicable requirements of 527 CMR and/or 248 CMR.

Defense: C.123 of the Acts of 2005 empowers the Board of Fire Prevention Regulations to promulgate CO Alarm requirements; additionally, the Fuel Gas and Plumbing Code (248 CMR) has CO alarm requirements for gas-fired appliances that are side-vented.